

Sampled	5/11/2025		Licensee:	Maitland City Council	
Published	17/11/2025		EPL #	6116	
Obtained					
Sampling Point	Monitoring Frequency	Pollutant	Measurement	Limit	Unit
Eastern Bank	Quarterly	Carbon Dioxide	0.1	NA	Volume %
	Quarterly	Oxygen	21.7	NA	Volume %
	Quarterly	Carbon Monoxide	0	NA	ppm
	Quarterly	Methane	0.1	1.25	Volume %
	Quarterly	Nitrogen	78.2	NA	Volume %
	Quarterly	Hydrogen Sulphide	0	NA	ppm
	Quarterly	CO:CO ₂	NC	NA	deff. Ratio
LMH3	Quarterly	Carbon Dioxide	0.8	NA	Volume %
	Quarterly	Oxygen	20.4	NA	Volume %
	Quarterly	Carbon Monoxide	0	NA	ppm
	Quarterly	Methane	1.4	1.25	Volume %
	Quarterly	Nitrogen	78.5	NA	Volume %
	Quarterly	Hydrogen Sulphide	0	NA	ppm
	Quarterly	CO:CO ₂	NC	NA	deff. Ratio
LMH6	Quarterly	Carbon Dioxide	0	NA	Volume %
	Quarterly	Oxygen	21.4	NA	Volume %
	Quarterly	Carbon Monoxide	0	NA	ppm
	Quarterly	Methane	0	1.25	Volume %
	Quarterly	Nitrogen	78.5	NA	Volume %
	Quarterly	Hydrogen Sulphide	1	NA	ppm
	Quarterly	CO:CO ₂	NC	NA	deff. Ratio
LMH7	Quarterly	Carbon Dioxide	0	NA	Volume %
	Quarterly	Oxygen	20.7	NA	Volume %
	Quarterly	Carbon Monoxide	0	NA	ppm
	Quarterly	Methane	0	1.25	Volume %
	Quarterly	Nitrogen	79.3	NA	Volume %
	Quarterly	Hydrogen Sulphide	0	NA	ppm
	Quarterly	CO:CO ₂	NC	NA	deff. Ratio
LMH13	Quarterly	Carbon Dioxide	4.3	NA	Volume %
	Quarterly	Oxygen	15.6	NA	Volume %
	Quarterly	Carbon Monoxide	0	NA	ppm
	Quarterly	Methane	0.1	NA	Volume %
	Quarterly	Nitrogen	80	NA	Volume %
	Quarterly	Hydrogen Sulphide	0	NA	ppm
	Quarterly	CO:CO ₂	NC	NA	deff. Ratio
LMH15	Quarterly	Carbon Dioxide	0.4	NA	Volume %
	Quarterly	Oxygen	20.9	NA	Volume %
	Quarterly	Carbon Monoxide	0	NA	ppm
	Quarterly	Methane	0	NA	Volume %
	Quarterly	Nitrogen	78.6	NA	Volume %
	Quarterly	Hydrogen Sulphide	0	NA	ppm
	Quarterly	CO:CO ₂	NC	NA	deff. Ratio